



464 Valley Brook Avenue, Lyndhurst NJ 07071  
129 Sea Girt Avenue, Manasquan NJ 08736  
Phone: (800) 423-0766 • Fax: (201) 438-1798  
www.mccabeenv.com

---

## LEAD IN DRINKING WATER TESTING REPORT

*Conducted for:*

Beloved Community Charter School  
508 Grand Street  
Jersey City, New Jersey 07302

*Conducted at:*

Beloved Community Charter School – High School & Middle School  
508 Grand Street  
Jersey City, New Jersey 07302

*Submitted by:*

McCabe Environmental Services, L.L.C.  
464 Valley Brook Avenue  
Lyndhurst, New Jersey 07071

**REPORT DATE:** January 6, 2022

**MES PROJECT NO.:** 21-04242

*Prepared by:*

A handwritten signature in black ink that reads 'Luke Giunta'.

**Luke Giunta**  
**Environmental Scientist**

*Signed for the Company by:*

A handwritten signature in blue ink that reads 'John H. Chiaviello'.

**John H. Chiaviello**  
**Vice President**

## **TABLE OF CONTENTS**

	<b>Page</b>
1.0 INTRODUCTION .....	1
2.0 SCOPE OF WORK.....	1
3.0 PROCEDURES.....	1
4.0 TABLE OF SAMPLE RESULTS .....	2
5.0 DISCUSSION AND CONCLUSION .....	4

### **APPENDIX A**

Laboratory Certificates of Analysis  
&  
Sample Chain of Custody Forms

### **APPENDIX B**

School District Sampling Attachments

**1.0 INTRODUCTION**

McCabe Environmental Services, L.L.C. (McCabe) was retained by Beloved Community Charter School (Client) to conduct lead in drinking water testing at 508 Grand Street, Jersey City, New Jersey 07302.

The project information is as follows:

Client Name: Beloved Community Charter School

Contact Person: Mr. Duane Moeller

Project Name: Beloved Community Charter School – Lead in Drinking Water Testing

Project Location: 508 Grand Street  
Jersey City, New Jersey 07302

Date(s) of Service: December 21, 2021

McCabe Personnel: Gary Clare & Luke Giunta

**2.0 SCOPE OF WORK**

Drinking water testing was performed at 508 Grand Street, Jersey City, New Jersey 07302 on December 21, 2021. The testing was limited to the High School and Middle School Buildings. The purpose of the testing was to determine if the building’s plumbing was having an adverse impact on water quality, specifically with regard to lead concentrations. Samples were collected from various potential drinking water outlets located throughout the building.

**3.0 PROCEDURES**

After determining which outlets would be sampled, McCabe personnel collected a "first draw" sample at each location. A "first draw" is the initial water that is first to come out of the tap after a period of inactivity. Following the “first draw”, a "30 second flush" sample was also collected where the main service line comes into the building. All samples were collected into 250 mL sterile bottles, labeled with a sample identification, and analyzed in accordance with EPA approved methods to determine the level of lead in drinking water. Samples were analyzed by an accredited laboratory.

The U.S. Environmental Protection Agency (EPA) has established National Primary Drinking Water Regulations (NPDWR) that set mandatory water quality standards for drinking water contaminants. These are enforceable standards called "maximum contaminant levels" or "MCL", which are established to protect the public against consumption of drinking water contaminants that present a risk to human health. An MCL is the maximum allowable amount of a contaminant in drinking water which is delivered to the consumer.

The EPA has established the Lead and Copper Rule that sets standards for state and public water systems. This rule has set an MCL for lead at 15 parts per billion (ppb) for a one liter sample. However, the EPA also established the Lead in Drinking Water at Schools and Child Care Facilities in which the EPA recommends an MCL of 20 ppb for a 250 milliliter first draw sample. In order to be more stringent, for our report purposes we have compared all results to both the 15 ppb and the 20 ppb standards.

**4.0 TABLE OF SAMPLE RESULTS**

The following table presents all sample results in order of sample identification:

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
01	Middle School First Floor Girl’s Bathroom Right Sink First Draw	< 0.5	Pass	Pass
02	Middle School 1 <sup>st</sup> Floor Girl’s Bathroom Right Sink 30 Second Flush	< 0.5	Pass	Pass
03	Middle School 1 <sup>st</sup> Floor Staff Bathroom Sink	< 0.5	Pass	Pass
04	Middle School 1 <sup>st</sup> Floor Boy’s Bathroom Left Sink	< 0.5	Pass	Pass
05	Middle School 1 <sup>st</sup> Floor Water Bottle Station	< 0.5	Pass	Pass
06	Middle School 2 <sup>nd</sup> Floor Break Room Sink	0.8	Pass	Pass
07	High School 1 <sup>st</sup> Floor Staff Bathroom Sink First Draw	< 0.5	Pass	Pass
08	High School 1 <sup>st</sup> Floor Staff Bathroom Sink 30 Second Flush	< 0.5	Pass	Pass
09	High School 2 <sup>nd</sup> Floor Kitchen Food Prep Sink Left of 3	< 0.5	Pass	Pass
10	High School 2 <sup>nd</sup> Floor Kitchen Food Prep Sink Left of 2	1	Pass	Pass
11	High School 2 <sup>nd</sup> Floor Kitchen Hand Washing Sink Near Entrance	0.9	Pass	Pass
12	High School 2 <sup>nd</sup> Floor Kitchen Food Prep Sink Center Island	< 0.5	Pass	Pass
13	High School 2 <sup>nd</sup> Floor Kitchen Hand Washing Sink Back Right Corner	0.6	Pass	Pass
<b>14</b>	<b>High School 2nd Floor Kitchen Hand Washing Sink Back Left Corner</b>	<b>18.9</b>	<b>Fail</b>	Pass
15	High School 2 <sup>nd</sup> Floor Food Service Room Food Prep Sink	< 0.5	Pass	Pass

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
16	High School 2 <sup>nd</sup> Floor Food Service Room Hand Washing Sink	2.1	Pass	Pass
17	High School 2 <sup>nd</sup> Floor Cafeteria Water Bottle Station	< 0.5	Pass	Pass
18	High School 2 <sup>nd</sup> Floor Men’s Room Center Sink	< 0.5	Pass	Pass
19	High School 2 <sup>nd</sup> Floor Women’s Room Center Sink	< 0.5	Pass	Pass
20	High School 2 <sup>nd</sup> Floor Water Bottle Station Near Nurses’ Office	< 0.5	Pass	Pass
21	High School 2 <sup>nd</sup> Floor Nurse’s Office Sink	2	Pass	Pass
22	High School 2 <sup>nd</sup> Floor Nurses’ Office Bathroom Sink	0.5	Pass	Pass
23	High School 2 <sup>nd</sup> Floor Staff Bathroom 110 Sink	< 0.5	Pass	Pass
24	High School 3 <sup>rd</sup> Floor Men’s Room 217 Sink Center	< 0.5	Pass	Pass
25	High School 3 <sup>rd</sup> Floor Women’s Room 215 Sink Center	< 0.5	Pass	Pass
26	High School 3 <sup>rd</sup> Floor Bottle Station Near 208B	< 0.5	Pass	Pass
27	High School 3 <sup>rd</sup> Floor Staff Bathroom 210	< 0.5	Pass	Pass
28	High School 4 <sup>th</sup> Floor Men’s Room 317 Sink Center	1.1	Pass	Pass
29	High School 4 <sup>th</sup> Floor Women’s Room 315 Sink Center	< 0.5	Pass	Pass
30	High School 4 <sup>th</sup> Floor Water Bottle Station Near 312	< 0.5	Pass	Pass
31	High School 4 <sup>th</sup> Floor Staff Bathroom 310 Sink	0.6	Pass	Pass
32	High School 4 <sup>th</sup> Floor Staff Bathroom 308 Sink	0.6	Pass	Pass

**5.0 DISCUSSION AND CONCLUSION**

A total of thirty-two (32) were collected from the Middle School and High School of the Beloved Community Charter School. One (1) sample was found to be greater than the EPA Lead and Copper Rule standard of 15 ppb but less than 20 ppb. All other samples were found to be less than the EPA standards of 20 ppb and 15 ppb. Listed below is the failed location.

- **High School 2nd Floor Kitchen Hand Washing Sink Back Left Corner**

McCabe recommends discontinued usage of the outlets which resulted in failed results until additional samples can be collected and analyzed and a permanent solution can be recommended. If handwashing is required at this location, it is recommended that the “DO NOT DRINK” sign provided in Appendix B be posted in clear view at the Kitchen Hand Washing Sink.

In addition, McCabe Environmental recommends annual drinking water sampling to ensure that the building’s plumbing is not having an adverse impact on water quality.

**APPENDIX A**

**LABORATORY CERTIFICATES OF ANALYSIS  
&  
SAMPLE CHAIN OF CUSTODY FORMS**



Tuesday, December 28, 2021

Attn: Jarred Panecki  
McCabe Environmental Services, LLC  
464 Valley Brook Avenue  
Lyndhurst, New Jersey 07071

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
SDG ID: GCK03214  
Sample ID#s: CK03214 - CK03245

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory. This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Sincerely yours,

A handwritten signature in black ink that reads "Phyllis Shiller". The signature is written in a cursive style with a large initial "P".

Phyllis Shiller

Laboratory Director

NELAC - #NY11301  
CT Lab Registration #PH-0618  
MA Lab Registration #M-CT007  
ME Lab Registration #CT-007  
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003  
NY Lab Registration #11301  
PA Lab Registration #68-03530  
RI Lab Registration #63  
UT Lab Registration #CT00007  
VT Lab Registration #VT11301





Environmental Laboratories, Inc.  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823



## Sample Id Cross Reference

December 28, 2021

SDG I.D.: GCK03214

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL

Client Id	Lab Id	Matrix
01	CK03214	DRINKING WATER
02	CK03215	DRINKING WATER
03	CK03216	DRINKING WATER
04	CK03217	DRINKING WATER
05	CK03218	DRINKING WATER
06	CK03219	DRINKING WATER
07	CK03220	DRINKING WATER
08	CK03221	DRINKING WATER
09	CK03222	DRINKING WATER
10	CK03223	DRINKING WATER
11	CK03224	DRINKING WATER
12	CK03225	DRINKING WATER
13	CK03226	DRINKING WATER
14	CK03227	DRINKING WATER
15	CK03228	DRINKING WATER
16	CK03229	DRINKING WATER
17	CK03230	DRINKING WATER
18	CK03231	DRINKING WATER
19	CK03232	DRINKING WATER
20	CK03233	DRINKING WATER
21	CK03234	DRINKING WATER
22	CK03235	DRINKING WATER
23	CK03236	DRINKING WATER
24	CK03237	DRINKING WATER
25	CK03238	DRINKING WATER
26	CK03239	DRINKING WATER
27	CK03240	DRINKING WATER
28	CK03241	DRINKING WATER
29	CK03242	DRINKING WATER
30	CK03243	DRINKING WATER



Environmental Laboratories, Inc.  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823



## Sample Id Cross Reference

December 28, 2021

SDG I.D.: GCK03214

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL

---

Client Id	Lab Id	Matrix
31	CK03244	DRINKING WATER
32	CK03245	DRINKING WATER



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

7:35  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03214

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 01

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			12/22/21	CPP	E200.8
Total Metal Digestion	Completed							12/21/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 28, 2021**

**Reviewed and Released by: Rashmi Makol, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

7:37  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03215

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 02

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			12/22/21	CPP	E200.8
Total Metal Digestion	Completed							12/21/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 28, 2021**

**Reviewed and Released by: Rashmi Makol, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

7:39  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03216

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 03

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			12/22/21	CPP	E200.8
Total Metal Digestion	Completed							12/21/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 28, 2021**

**Reviewed and Released by: Rashmi Makol, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

7:45  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03217

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 04

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			12/22/21	CPP	E200.8
Total Metal Digestion	Completed							12/21/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 28, 2021**

**Reviewed and Released by: Rashmi Makol, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

7:41  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03218

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 05

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			12/22/21	CPP	E200.8
Total Metal Digestion	Completed							12/21/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 28, 2021**

**Reviewed and Released by: Rashmi Makol, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

7:43  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03219

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 06

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.8	0.5	2	ppb	15			12/22/21	CPP	E200.8
Total Metal Digestion	Completed							12/21/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 28, 2021**

**Reviewed and Released by: Rashmi Makol, Project Manager**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

7:49  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03220

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 07

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			12/22/21	CPP	E200.8
Total Metal Digestion	Completed							12/21/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 28, 2021**

**Reviewed and Released by: Rashmi Makol, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

7:51  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03221

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 08

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			12/22/21	CPP	E200.8
Total Metal Digestion	Completed							12/21/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 28, 2021**

**Reviewed and Released by: Rashmi Makol, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

7:52  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03222

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 09

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			12/22/21	CPP	E200.8
Total Metal Digestion	Completed							12/21/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 28, 2021**

**Reviewed and Released by: Rashmi Makol, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

7:53  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03223

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 10

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1	0.5	2	ppb	15			12/23/21	CPP	E200.8
Total Metal Digestion	Completed							12/21/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 28, 2021**

**Reviewed and Released by: Rashmi Makol, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

7:54  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03224

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 11

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.9	0.5	2	ppb	15			12/23/21	CPP	E200.8
Total Metal Digestion	Completed							12/21/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 28, 2021**

**Reviewed and Released by: Rashmi Makol, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

7:54  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03225

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 12

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			12/23/21	CPP	E200.8
Total Metal Digestion	Completed							12/22/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 28, 2021**

**Reviewed and Released by: Rashmi Makol, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

7:55  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03226

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 13

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.6	0.5	2	ppb	15			12/23/21	CPP	E200.8
Total Metal Digestion	Completed							12/22/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 28, 2021**

**Reviewed and Released by: Rashmi Makol, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

7:56  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03227

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 14

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	18.9	0.5	2	ppb	15			12/23/21	CPP	E200.8
*** Lead exceeds Action Level of 15 ***										
Total Metal Digestion	Completed							12/22/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 28, 2021

Reviewed and Released by: Rashmi Makol, Project Manager





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

7:58  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03228

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 15

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			12/23/21	CPP	E200.8
Total Metal Digestion	Completed							12/21/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 28, 2021**

**Reviewed and Released by: Rashmi Makol, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

7:58  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03229

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 16

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	2.1	0.5	2	ppb	15			12/23/21	CPP	E200.8
Total Metal Digestion	Completed							12/22/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 28, 2021**

**Reviewed and Released by: Rashmi Makol, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

8:00  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03230

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 17

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			12/23/21	CPP	E200.8
Total Metal Digestion	Completed							12/22/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 28, 2021**

**Reviewed and Released by: Rashmi Makol, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

8:01  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03231

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 18

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			12/23/21	CPP	E200.8
Total Metal Digestion	Completed							12/22/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 28, 2021**

**Reviewed and Released by: Rashmi Makol, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

8:01  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03232

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 19

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			12/23/21	CPP	E200.8
Total Metal Digestion	Completed							12/21/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 28, 2021**

**Reviewed and Released by: Rashmi Makol, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

8:02  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03233

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 20

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			12/23/21	CPP	E200.8
Total Metal Digestion	Completed							12/21/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 28, 2021

Reviewed and Released by: Rashmi Makol, Project Manager



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

7:35  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03234

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 21

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	2	0.5	2	ppb	15			12/23/21	CPP	E200.8
Total Metal Digestion	Completed							12/21/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 28, 2021**

**Reviewed and Released by: Rashmi Makol, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

8:04  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03235

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 22

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.5	0.5	2	ppb	15			12/23/21	CPP	E200.8
Total Metal Digestion	Completed							12/21/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 28, 2021**

**Reviewed and Released by: Rashmi Makol, Project Manager**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

8:05  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03236

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 23

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			12/23/21	CPP	E200.8
Total Metal Digestion	Completed							12/21/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 28, 2021**

**Reviewed and Released by: Rashmi Makol, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

8:06  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03237

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 24

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			12/23/21	CPP	E200.8
Total Metal Digestion	Completed							12/21/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 28, 2021**

**Reviewed and Released by: Rashmi Makol, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

8:06  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03238

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 25

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			12/23/21	CPP	E200.8
Total Metal Digestion	Completed							12/21/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 28, 2021**

**Reviewed and Released by: Rashmi Makol, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

8:07  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03239

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 26

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			12/23/21	CPP	E200.8
Total Metal Digestion	Completed							12/21/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 28, 2021**

**Reviewed and Released by: Rashmi Makol, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

8:08  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03240

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 27

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			12/23/21	CPP	E200.8
Total Metal Digestion	Completed							12/21/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 28, 2021**

**Reviewed and Released by: Rashmi Makol, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

8:10  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03241

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 28

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.1	0.5	2	ppb	15			12/23/21	CPP	E200.8
Total Metal Digestion	Completed							12/21/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 28, 2021**

**Reviewed and Released by: Rashmi Makol, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

8:12  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03242

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 29

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			12/23/21	CPP	E200.8
Total Metal Digestion	Completed							12/21/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 28, 2021**

**Reviewed and Released by: Rashmi Makol, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

8:13  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03243

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 30

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			12/23/21	CPP	E200.8
Total Metal Digestion	Completed							12/21/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 28, 2021**

**Reviewed and Released by: Rashmi Makol, Project Manager**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

8:18  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03244

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 31

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.6	0.5	2	ppb	15			12/23/21	CPP	E200.8
Total Metal Digestion	Completed							12/21/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 28, 2021**

**Reviewed and Released by: Rashmi Makol, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



**Analysis Report**  
 December 28, 2021

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: SW  
 Analyzed by: see "By" below

Date

12/21/21  
 12/21/21

Time

8:19  
 14:53

Laboratory Data

SDG ID: GCK03214  
 Phoenix ID: CK03245

Project ID: 21-04242 BELOVED COMMUNITY CHARTER SCHL  
 Client ID: 32

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.6	0.5	2	ppb	15			12/23/21	CPP	E200.8
Total Metal Digestion	Completed							12/21/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 28, 2021**

**Reviewed and Released by: Rashmi Makol, Project Manager**

# Analysis Report - Summary

December 28, 2021

Attn: Jarred Panecki  
McCabe Environmental Services, LLC  
464 Valley Brook Avenue  
Lyndhurst, New Jersey 07071



Environmental Laboratories, Inc.  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823

SDG I.D.: GCK03214




Sample	Client Id	Col Date	Parameter	Result	RL	Units	Date Analyzed	Reference
Project: 21-04242 Beloved Community Charter Schl								
CK03214	01	12/21/21	Lead	< 0.5	0.5	ppb	12/22/21	E200.8
CK03215	02	12/21/21	Lead	< 0.5	0.5	ppb	12/22/21	E200.8
CK03216	03	12/21/21	Lead	< 0.5	0.5	ppb	12/22/21	E200.8
CK03217	04	12/21/21	Lead	< 0.5	0.5	ppb	12/22/21	E200.8
CK03218	05	12/21/21	Lead	< 0.5	0.5	ppb	12/22/21	E200.8
CK03219	06	12/21/21	Lead	0.8	0.5	ppb	12/22/21	E200.8
CK03220	07	12/21/21	Lead	< 0.5	0.5	ppb	12/22/21	E200.8
CK03221	08	12/21/21	Lead	< 0.5	0.5	ppb	12/22/21	E200.8
CK03222	09	12/21/21	Lead	< 0.5	0.5	ppb	12/22/21	E200.8
CK03223	10	12/21/21	Lead	1	0.5	ppb	12/23/21	E200.8
CK03224	11	12/21/21	Lead	0.9	0.5	ppb	12/23/21	E200.8
CK03225	12	12/21/21	Lead	< 0.5	0.5	ppb	12/23/21	E200.8
CK03226	13	12/21/21	Lead	0.6	0.5	ppb	12/23/21	E200.8
CK03227	14	12/21/21	Lead	18.9	0.5	ppb	12/23/21	E200.8
CK03228	15	12/21/21	Lead	< 0.5	0.5	ppb	12/23/21	E200.8
CK03229	16	12/21/21	Lead	2.1	0.5	ppb	12/23/21	E200.8
CK03230	17	12/21/21	Lead	< 0.5	0.5	ppb	12/23/21	E200.8
CK03231	18	12/21/21	Lead	< 0.5	0.5	ppb	12/23/21	E200.8
CK03232	19	12/21/21	Lead	< 0.5	0.5	ppb	12/23/21	E200.8
CK03233	20	12/21/21	Lead	< 0.5	0.5	ppb	12/23/21	E200.8
CK03234	21	12/21/21	Lead	2	0.5	ppb	12/23/21	E200.8
CK03235	22	12/21/21	Lead	0.5	0.5	ppb	12/23/21	E200.8
CK03236	23	12/21/21	Lead	< 0.5	0.5	ppb	12/23/21	E200.8
CK03237	24	12/21/21	Lead	< 0.5	0.5	ppb	12/23/21	E200.8
CK03238	25	12/21/21	Lead	< 0.5	0.5	ppb	12/23/21	E200.8

Sample	Client Id	Col Date	Parameter	Result	RL	Units	Date Analyzed	Reference
CK03239	26	12/21/21	Lead	< 0.5	0.5	ppb	12/23/21	E200.8
CK03240	27	12/21/21	Lead	< 0.5	0.5	ppb	12/23/21	E200.8
CK03241	28	12/21/21	Lead	1.1	0.5	ppb	12/23/21	E200.8
CK03242	29	12/21/21	Lead	< 0.5	0.5	ppb	12/23/21	E200.8
CK03243	30	12/21/21	Lead	< 0.5	0.5	ppb	12/23/21	E200.8
CK03244	31	12/21/21	Lead	0.6	0.5	ppb	12/23/21	E200.8
CK03245	32	12/21/21	Lead	0.6	0.5	ppb	12/23/21	E200.8

Comments:

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 ND=Not detected BDL=Below Detection Level RL=Reporting Level CL=Client Limit

  
 Phyllis Shiller  
 Laboratory Director  
 December 28, 2021



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



# QA/QC Report

December 28, 2021

## QA/QC Data

SDG I.D.: GCK03214

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	--------	---------------	------------	---------	-------	--------	---------	------	-------	--------	--------------	--------------

QA/QC Batch 605548 (mg/L), QC Sample No: CK03214 2X (CK03214, CK03215, CK03216, CK03217, CK03218, CK03219, CK03220, CK03221, CK03222, CK03223)

### ICP MS Metals - Aqueous

Lead BRL 0.0001 <0.0005 0.0001 NC 104 93.8

QA/QC Batch 605548A (mg/L), QC Sample No: CK03224 2X (CK03224, CK03228, CK03232, CK03233, CK03234, CK03235, CK03236, CK03237, CK03238, CK03239)

### ICP MS Metals - Aqueous

Lead BRL 0.0001 104 95.2

Comment:

This batch does not include a duplicate.

QA/QC Batch 605732 (mg/L), QC Sample No: CK03225 2X (CK03225, CK03226, CK03227, CK03229, CK03230, CK03231)

### ICP MS Metals - Aqueous

Lead BRL 0.0001 <0.0005 0.0001 NC 99.4 94.2


QA/QC Batch 605550 (mg/L), QC Sample No: CK03240 2X (CK03240, CK03241, CK03242, CK03243, CK03244, CK03245)

### ICP MS Metals - Aqueous

Lead BRL 0.0001 <0.0005 0.0004 NC 105 101

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Intf - Interference

  
 Phyllis Shiller, Laboratory Director  
 December 28, 2021

Tuesday, December 28, 2021

Criteria: NJ: DW

State: NJ

## Sample Criteria Exceedances Report

GCK03214 - MCCABE-PB

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
CK03227	PB-DW-MS	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	18.9	0.5	15	1	ppb

Phoenix Laboratories does not assume responsibility for the data contained in this exceedance report. It is provided as an additional tool to identify requested criteria exceedences. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



**Environmental Laboratories, Inc.**  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823



## Analysis Comments

December 28, 2021

SDG I.D.: GCK03214

---

The following analysis comments are made regarding exceptions to criteria not already noted in the Analysis Report or QA/QC Report: None.

**MCCABE ENVIRONMENTAL SERVICES, L.L.C.**

464 VALLEY BROOK AVENUE LYNDBURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

3.0wair

**LEAD in DRINKING WATER  
CHAIN-OF-CUSTODY FORM**

<b>CLIENT NAME:</b> Beloved Community Charter School		<b>SITE ADDRESS:</b> 508 Grand Street, Jersey City, New Jersey 07302		
<b>FIELD INSPECTOR'S NAME:</b> Gary Clare & Luke Giunta		<b>TURNAROUND TIME REQUESTED:</b> 2 week TAT		
<b>MES PROJECT #:</b> 21-04242		<b>SAMPLE DATE:</b> 12/21/21		
Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW	01	Middle School 1st Floor Girl's Bathroom Right Sink first draw	7:35 AM	LEAD - 200.8
DW	02	Middle School 1st Floor Girl's Bathroom Right Sink 30 second flush	7:37 AM	LEAD - 200.8
DW	03	Middle School 1st Floor Staff Bathroom Sink	7:39 AM	LEAD - 200.8
DW	04	Middle School 1st Floor Boy's Bathroom Left Sink	7:40 AM	LEAD - 200.8
DW	05	Middle School 1st Floor Water bottle station	7:41 AM	LEAD - 200.8
DW	06	Middle School 2nd Floor Breakroom sink	7:43 AM	LEAD - 200.8
DW	07	High School 1st Floor Staff Bathroom Sink first draw	7:49 AM	LEAD - 200.8
DW	08	High School 1st Floor Staff Bathroom Sink 30 second flush	7:51 AM	LEAD - 200.8
DW	09	High School 2nd Floor Kitchen food prep sink left of 3	7:52 AM	LEAD - 200.8
DW	10	High School 2nd Floor Kitchen food prep sink right of 2	7:53 AM	LEAD - 200.8
<b>Relinquished by (Print)</b> Luke Giunta		<b>Date:</b> 12/21/21	<b>Time:</b>	<b>Date:</b> 12/21
<b>Signature:</b> <i>Luke Giunta</i>		<b>Received by: (Print)</b> Matthew Dym	<b>Signature:</b> <i>Matthew Dym</i>	<b>Time:</b> 1136
<b>Relinquished by (Print)</b> <i>Matthew Dym</i>		<b>Date:</b>	<b>Time:</b>	<b>Date:</b> 12/21
<b>Signature:</b> <i>Matthew Dym</i>		<b>Received by: (Print)</b> Sierra Raab	<b>Signature:</b> <i>Sierra Raab</i>	<b>Time:</b> 14:53
<b>Laboratory Analysis Performed by (Analyst Signature, Laboratory Name &amp; Location):</b> Phoenix Environmental Laboratories				

NJ Certified WBE



MCCABE ENVIRONMENTAL SERVICES, L.L.C.

464 VALLEY BROOK AVENUE LYNDBURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

3.0wcap

LEAD in DRINKING WATER  
CHAIN-OF-CUSTODY FORM

CLIENT NAME: Beloved Community Charter School		SITE ADDRESS: 508 Grand Street, Jersey City, New Jersey 07302		
FIELD INSPECTOR'S NAME: Gary Clare & Luke Giunta		TURNAROUND TIME REQUESTED: 2 week TAT		
MES PROJECT #: 21-04242	SAMPLE DATE: 12/21/21			
Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW	11	High School 2nd floor kitchen hand washing sink near entrance	7:54 AM	LEAD - 200.8
DW	12	High School 2nd floor kitchen food prep sink center island	7:54 AM	LEAD - 200.8
DW	13	High School 2nd floor kitchen hand washing sink back right corner	7:55 AM	LEAD - 200.8
DW	14	High School 2nd floor kitchen hand washing sink back left corner	7:56 AM	LEAD - 200.8
DW	15	High School 2nd floor Food Service Room Food Prep sink	7:58 AM	LEAD - 200.8
DW	16	High School 2nd floor Food Service Room food washing sink	7:58 AM	LEAD - 200.8
DW	17	High School 2nd floor Cafeteria Water bottle Station	8:00 AM	LEAD - 200.8
DW	18	High School 2nd floor Men's room Water Sink	8:01 AM	LEAD - 200.8
DW	19	High School 2nd floor Women's room Water Sink	8:01 AM	LEAD - 200.8
DW	20	High School 2nd floor Water Bottle Station near Nursing Office	8:02 AM	LEAD - 200.8
Relinquished by (Print) Luke Giunta		Date:	12/21/21	Time:
Signature: <i>Luke Giunta</i>		Received by: (Print) <i>Matthew Dorn</i>	Date:	12/21/21
		Signature: <i>Matthew Dorn</i>	Date:	11:36
Relinquished by (Print) <i>Luke Giunta</i>		Received by: (Print) <i>Sierra Reed</i>	Date:	12/21/21
Signature: <i>Luke Giunta</i>		Signature: <i>Sierra Reed</i>	Date:	14:53
Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories				

NJ Certified WBE

**MCCABE ENVIRONMENTAL SERVICES, L.L.C.**

464 VALLEY BROOK AVENUE LYNTHURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

3.0 WAP

**LEAD in DRINKING WATER  
CHAIN-OF-CUSTODY FORM**

<b>CLIENT NAME:</b> Beloved Community Charter School		<b>SITE ADDRESS:</b> 508 Grand Street, Jersey City, New Jersey 07302		
<b>FIELD INSPECTOR'S NAME:</b> Gary Clare & Luke Giunta		<b>TURNAROUND TIME REQUESTED:</b>		
<b>MES PROJECT #:</b> 21-04242		2 week FAT		
<b>SAMPLE DATE:</b> 12/21/21				
Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW	21	High School 2nd Floor Nurse's Office Sink	8:24 AM	LEAD - 200.8
DW	22	High School 2nd Floor Nurse's Office Restroom Sink	8:24 AM	LEAD - 200.8
DW	23	High School 2nd Floor Staff Restroom 110 Sink	8:05 AM	LEAD - 200.8
DW	24	High School 3rd Floor Men's Room 217 sink center	8:06 AM	LEAD - 200.8
DW	25	High School 3rd Floor Women's Room 215 sink center	8:05 AM	LEAD - 200.8
DW	26	High School 3rd Floor Bottle Station 208B	8:07 AM	LEAD - 200.8
DW	27	High School 3rd Floor Staff Restroom 210	8:08 AM	LEAD - 200.8
DW	28	High School 4th Floor Men's Room 317 sink center	8:10 AM	LEAD - 200.8
DW	29	High School 4th Floor Women's Room 315 sink center	8:12 AM	LEAD - 200.8
DW	30	High School 4th Floor Water Bottle Station near 312	8:13 AM	LEAD - 200.8
<b>Relinquished by (Print)</b> Luke Giunta		<b>Date:</b> 12/21/21	<b>Time:</b>	<b>Date:</b> 12/21
<b>Signature:</b> <i>Luke Giunta</i>		<b>Received by: (Print)</b> Matthew Down	<b>Signature:</b> <i>Matthew Down</i>	<b>Time:</b> 11:38
<b>Relinquished by (Print)</b> Gary Clare		<b>Date:</b>	<b>Time:</b>	<b>Date:</b> 12/21
<b>Signature:</b> <i>Gary Clare</i>		<b>Received by: (Print)</b> Sierra Raab	<b>Signature:</b> <i>Sierra Raab</i>	<b>Time:</b> 14:53
<b>Laboratory Analysis Performed by (Analyst Signature, Laboratory Name &amp; Location):</b> Phoenix Environmental Laboratories				

**MCCABE ENVIRONMENTAL SERVICES, L.L.C.**

464 VALLEY BROOK AVENUE LYNTHURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

3.0 wca19

**LEAD in DRINKING WATER  
CHAIN-OF-CUSTODY FORM**

CLIENT NAME: Beloved Community Charter School  
 SITE ADDRESS: 508 Grand Street, Jersey City, New Jersey 07302

FIELD INSPECTOR'S NAME: Gary Clare & Luke Giunta  
 TURNAROUND TIME REQUESTED:  
 MES PROJECT #: 21-04242  
 SAMPLE DATE: 12/21/21  
 2 weeks TAT

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW	31	High School 4th Floor Staff Breakroom 310 sink	8:18 AM	LEAD - 200.8
DW	32	High School 4th floor Staff Bathroom 308 sink	8:19 AM	LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8

Relinquished by (Print) Luke Giunta  
 Signature: Luke Giunta  
 Date: 12/21/21  
 Time: 11:36  
 Received by: (Print) Matthew D...  
 Signature: [Signature]  
 Relinquished by (Print) Matthew D...  
 Signature: [Signature]  
 Date: 12/21  
 Time: 14:53  
 Received by: (Print) Sierra Raab  
 Signature: [Signature]

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

**APPENDIX B**

**SCHOOL DISTRICT SAMPLING ATTACHMENTS**

## Attachment A - List of Priority for Sampling

SCHOOL NAME	DATE OF SAMPLING	CERTIFIED LABORATORY	NOTES
Beloved Community Charter School	12/21/2021	Phoenix Environmental Laboratories Inc.	

## Attachment B – Plumbing Profile

**Note:** Complete for each school. For additional information see the USEPA publication, “The 3Ts for Reducing Lead in Drinking Water in Schools”

Name of School: Beloved Community Charter School

Grade Levels: K-10

Address: 508 Grand Street, Jersey City, New Jersey 07302

Individual school project officer Signature: Duanne Moeller

Date: 11/23/21

Questions	Answers	
<b>Background Information</b>		
1. What year was the original building constructed? Were any buildings or additions added to the original facility?	Main: 2000 Annex:2014	Middle School: 2017 High School:2019 New MPR: 2021
2. If the building was constructed or repaired after 1986, was lead-free plumbing and solder utilized? What type of solder was used? Document all locations where lead solder was used.		
3. Where are the most recent plumbing repairs and replacements?	Location: New MPR Annex: Replaced Kitchen Water Heater	Description: Added MPR, only one Plumbing fixture. Water fountain.
4. With what materials is the service connection (the pipe that carries water to the school from the public water system’s main in the street) made? Where is the Service Line located? (This is the POE location.)	Material: Galvanized pipe (Presumed)  Location: Comes into Building from Grand Street at Front of Building.	
5. Is there point of entry (POE) or point of use (POU) treatment in use?	Y / <b>(N)</b> Type:	Location:

Questions	Answers
6. Are there tanks in your plumbing system (pressure tanks, gravity storage tanks)?	<input checked="" type="radio"/> Y / N
7. Does the school have a filter maintenance and operation program? If so, who is responsible for this program? What is the process for adding filters?	Only for the water fountains and High School Kitchen. Water fountain filters are replaced when the light comes on. High School filters on ice maker and steamer are replaced every six months.
8. Have accessible screens or aerators on outlets that provide drinking water been cleaned? Does the school have a screen or aerator maintenance program?	Y / <input checked="" type="radio"/> N
9. Have there been any complaints about bad (metallic) taste? Note location(s).	Y / <input checked="" type="radio"/> N Location:
10. Review records and consult with the public water supplier to determine whether any water samples have been taken in the building for any contaminants. If so, identify: <ul style="list-style-type: none"> <li>• Name of contaminant(s)</li> <li>• Concentrations found</li> <li>• pH level</li> </ul> Is testing done regularly at the building?	
11. Other plumbing background questions include: <ul style="list-style-type: none"> <li>• Are blueprints of the building available?</li> <li>• Are there known plumbing “dead-ends”, low use areas, existing leaks or other “problem areas”?</li> </ul> Are renovations planned for any of the plumbing system?	Blueprints are available. There are no know “dead-ends” in the system. No plumbing renovations are planned.

Questions	Answers	
<p><b>Walk-Through</b>  <i>These questions should be addressed during the walk-through of the facility, while Attachment C- Drinking Water Outlet Inventory is being completed.</i></p>		
1. Confirm the material of Service Line visually.	N/A	
2. Confirm the presence of POE or POU treatment.	N/A	
<p>3. What are the potable water pipes made of in your facility?</p> <ul style="list-style-type: none"> <li>• Lead</li> <li>• Plastic</li> <li>• Galvanized Metal</li> <li>• Cast Iron</li> <li>• Copper</li> <li>• Other</li> </ul> <p>Note the water flow through the building and the areas that receive water first, and which areas receive water last.</p>	N/A	
<p>4. Are electrical wires grounded to Water Pipes?  Note location(s).</p>	Y / <b>(N)</b> N/A Location:	
<p>5. Are brass fittings, faucets, or valves used in your drinking water system?  Note that most faucets are brass on the inside.  Document the locations of any brass water outlet to be sampled.</p>	Complete in “Brass” Column in Attachment C- Water Outlet Inventory.	
<p>6. Locate all drinking water outlets (i.e. water coolers, bubblers, ice machines, kitchen/ food prep sinks, etc.) in the facility.</p>	Complete in Attachment C-Water Outlet Inventory.	



Questions	Answers	
<p>7. Have the brands and models of the water coolers in the school been compared to the list of recalled water coolers in the Toolkit?</p> <p>Recalled Drinking Water Fountains</p> <p>Make and Model</p>	<p>Y / N</p> <p>N/A</p> <p>Type</p>	
<p>8. Have signs of corrosion, such as frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry been detected?</p> <p>Note the locations of water outlets.</p>	<p>Complete in "Signs of Corrosion" column in Attachment C- Drinking Water Outlet Inventory.</p>	
<p>9. Are there any outlets that are not operational and therefore out of service? Permanently? Temporarily?</p> <p style="text-align: right;">Permanently</p> <p style="text-align: right;">Temporarily</p>	<p>Y / N</p> <p>Complete "Operational Column" in Attachment C- Drinking Water Outlet Inventory.</p> <p>Type/ Location</p>	<p>Description</p>

## Attachment C – Drinking Water Outlet Inventory

Name of School: Beloved Community Charter School

Address: 508 Grand Street, Jersey City, New Jersey 07302

Grade Levels: Middle School and High School

Year School Constructed: 2017 & 2019

Renovated/Additions: N/A

Individual school project officer Name/Signature: Duane Moeller

Date Completed: 01/04/2022

# <sup>1</sup>	Type	Location	Code	Operational <sup>2</sup> (Y/N)	Signs of Corrosion <sup>3</sup> (Y/N)	Filter <sup>4</sup> (Y/N)	Brass Fittings, Faucets or valves? (Y/N)	Aerator/ Screen (Y/N)	Motion Activated (Y/N)	Chiller (Y/N)	Water Cooler		Comments
											Make	Model	
01	Sink	Middle School First Floor Girl's Bathroom Right Sink First Draw	01	Y	N	N	N	Y	N	N	NA	NA	
02	Sink	Middle School 1st Floor Girl's Bathroom Right Sink 30 Second Flush	02	Y	N	N	N	Y	N	N	NA	NA	
03	Sink	Middle School 1st Floor Staff Bathroom Sink	03	Y	N	N	N	Y	N	N	NA	NA	

<sup>1</sup> Number outlets starting at the closest outlet to the Point of Entry (POE).

<sup>2</sup> Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.

<sup>3</sup> Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.

<sup>4</sup> Document on Attachment D- Filter Inventory.

04	Sink	Middle School 1st Floor Boy's Bathroom Left Sink	04	Y	N	N	N	Y	N	N	NA	NA	
05	Fountain	Middle School 1st Floor Water Bottle Station	05	Y	N	Y	N	N	Y	Y	Elkay	EZFSTL B 1H	
06	Sink	Middle School 2nd Floor Break Room Sink	06	Y	N	N	N	Y	N	N	NA	NA	
07	Sink	High School 1st Floor Staff Bathroom Sink First Draw	07	Y	N	N	N	Y	N	N	NA	NA	
08	Sink	High School 1st Floor Staff Bathroom Sink 30 Second Flush	08	Y	N	N	N	Y	N	N	NA	NA	
09	Sink	High School 2nd Floor Kitchen Food Prep Sink Left of 3	09	Y	N	N	N	N	N	N	NA	NA	
10	Sink	High School 2nd Floor Kitchen Food Prep Sink Left of 2	10	Y	N	N	N	N	N	N	NA	NA	
11	Sink	High School 2nd Floor Kitchen Hand Washing Sink Near Entrance	11	Y	N	N	N	N	N	N	NA	NA	
12	Sink	High School 2nd Floor Kitchen Food	12	Y	N	N	N	N	N	N	NA	NA	

		Prep Sink Center Island											
13	Sink	High School 2nd Floor Kitchen Hand Washing Sink Back Right Corner	13	Y	N	N	N	N	N	N	NA	NA	
14	Sink	High School 2nd Floor Kitchen Hand Washing Sink Back Left Corner	14	Y	N	N	N	N	N	Y	NA	NA	
15	Sink	High School 2nd Floor Food Service Room Food Prep Sink	15	Y	N	N	N	N	N	N	NA	NA	
16	Sink	High School 2nd Floor Food Service Room Hand Washing Sink	16	Y	N	N	N	N	N	N	NA	NA	
17	Fountain	High School 2nd Floor Cafeteria Water Bottle Station	17	Y	N	Y	N	N	Y	Y	Elkay	EZFSTL B 1H	
18	Sink	High School 2nd Floor Men's Room Center Sink	18	Y	N	N	N	Y	N	N	NA	NA	
19	Sink	High School 2nd Floor Women's Room Center Sink	19	Y	N	N	N	Y	N	N	NA	NA	
20	Fountain	High School 2nd Floor Water Bottle	20	Y	N	Y	N	N	Y	Y	Elkay	EZFSTL B 1H	

		Station Near Nurses' Office											
21	Sink	High School 2nd Floor Nurse's Office Sink	21	Y	N	N	N	Y	N	N	NA	NA	
22	Sink	High School 2nd Floor Nurses' Office Bathroom Sink	22	Y	N	N	N	Y	N	N	NA	NA	
23	Sink	High School 2nd Floor Staff Bathroom 110 Sink	23	Y	N	N	N	Y	N	N	NA	NA	
24	Sink	High School 3rd Floor Men's Room 217 Sink Center	24	Y	N	N	N	Y	N	N	NA	NA	
25	Sink	High School 3rd Floor Women's Room 215 Sink Center	25	Y	N	N	N	Y	N	N	NA	NA	
26	Fountain	High School 3rd Floor Bottle Station Near 208B	26	Y	N	Y	N	N	Y	Y	Elkay	EZFSTL B 1H	
27	Sink	High School 3rd Floor Staff Bathroom 210	27	Y	N	N	N	Y	N	N	NA	NA	
28	Sink	High School 4th Floor Men's Room 317 Sink Center	28	Y	N	N	N	Y	N	N	NA	NA	
29	Sink	High School 4th Floor Women's	29	Y	N	N	N	Y	N	N	NA	NA	

		Room 315 Sink Center											
30	Fountain	High School 4th Floor Water Bottle Station Near 312	30	Y	N	Y	N	N		Y	Elkay	EZFSTL B 1H	
31	Sink	High School 4th Floor Staff Bathroom 310 Sink	31	Y	N	N	N	Y		N	NA	NA	
32	Sink	High School 4th Floor Staff Bathroom 308 Sink	32	Y	N	N	N	Y		N	NA	NA	

**Attachment D - Filter Inventory**

Name of School: Beloved Community Charter School Grade Levels: Middle School and High School

Address: 508 Grand Street, Jersey City, New Jersey 07302

Individual School Project Officer Signature: Duane Moeller

Date: 01/04/2022

Sample Location / Code	Brand	Type (Make & Model)	Date Installed or Replaced	Replacement Frequency	NSF Certified for Lead Reduction Y/N
01	Zurn	NA	NA	NA	NA
02	Zurn	NA	NA	NA	NA
03	Zurn	NA	NA	NA	NA
04	Zurn	NA	NA	NA	NA
05	Elkay	EZFSTL B 1H	NA	NA	NA
06	Zurn	NA	NA	NA	NA
07	Zurn	NA	NA	NA	NA
08	Zurn	NA	NA	NA	NA
09	BK	NA	NA	NA	NA
10	BK	NA	NA	NA	NA
11	BK	NA	NA	NA	NA
12	BK	NA	NA	NA	NA
13	BK	NA	NA	NA	NA
14	BK	NA	NA	NA	NA
15	BK	NA	NA	NA	NA
16	BK	NA	NA	NA	NA
17	Elkay	EZFSTL B 1H	NA	NA	NA
18	Zurn	NA	NA	NA	NA
19	Zurn	NA	NA	NA	NA
20	Elkay	EZFSTL B 1H	NA	NA	NA
21	Zurn	NA	NA	NA	NA
22	Zurn	NA	NA	NA	NA

Beloved Community Charter School Sampling Plan

Date: 01/06/2022

23	Zurn	NA	NA	NA	NA
24	Zurn	NA	NA	NA	NA
25	Zurn	NA	NA	NA	NA
26	Elkay	EZFSTL B 1H	NA	NA	NA
27	Zurn	NA	NA	NA	NA
28	Zurn	NA	NA	NA	NA
29	Zurn	NA	NA	NA	NA
30	Elkay	EZFSTL B 1H	NA	NA	NA
31	Zurn	NA	NA	NA	NA
32	Zurn	NA	NA	NA	NA



**Attachment E – Flushing Log**Name of School: Beloved Community Charter SchoolAddress: 508 Grand Street, Jersey City, New Jersey 07302Grade Levels: Middle School and High SchoolIndividual School Project Officer Signature: Duanne MoellerDate: 01/06/2022

Sample Location Description	Sample Location Code	Date	Time	Duration of Flushing	Reason for Flushing
Middle School First Floor Girl's Bathroom Right Sink First Draw	01	12/21/2021	7:35 AM	2-3 Minutes	Water Sampling
Middle School 1st Floor Girl's Bathroom Right Sink 30 Second Flush	02	12/21/2021	7:37 AM	2-3 Minutes	Water Sampling
Middle School 1st Floor Staff Bathroom Sink	03	12/21/2021	7:39 AM	2-3 Minutes	Water Sampling
Middle School 1st Floor Boy's Bathroom Left Sink	04	12/21/2021	7:40 AM	2-3 Minutes	Water Sampling
Middle School 1st Floor Water Bottle Station	05	12/21/2021	7:41 AM	2-3 Minutes	Water Sampling
Middle School 2nd Floor Break Room Sink	06	12/21/2021	7:43 AM	2-3 Minutes	Water Sampling
High School 1st Floor Staff Bathroom Sink First Draw	07	12/21/2021	7:49 AM	2-3 Minutes	Water Sampling

## Beloved Community Charter School Sampling Plan

Date: 01/06/2022

High School 1st Floor Staff Bathroom Sink 30 Second Flush	08	12/21/2021	7:51 AM	2-3 Minutes	Water Sampling
High School 2nd Floor Kitchen Food Prep Sink Left of 3	09	12/21/2021	7:52 AM	2-3 Minutes	Water Sampling
High School 2nd Floor Kitchen Food Prep Sink Left of 2	10	12/21/2021	7:53 AM	2-3 Minutes	Water Sampling
High School 2nd Floor Kitchen Hand Washing Sink Near Entrance	11	12/21/2021	7:54 AM	2-3 Minutes	Water Sampling
High School 2nd Floor Kitchen Food Prep Sink Center Island	12	12/21/2021	7:54 AM	2-3 Minutes	Water Sampling
High School 2nd Floor Kitchen Hand Washing Sink Back Right Corner	13	12/21/2021	7:55 AM	2-3 Minutes	Water Sampling
High School 2nd Floor Kitchen Hand Washing Sink Back Left Corner	14	12/21/2021	7:56 AM	2-3 Minutes	Water Sampling
High School 2nd Floor Food Service Room Food Prep Sink	15	12/21/2021	7:58 AM	2-3 Minutes	Water Sampling
High School 2nd Floor Food Service Room Hand Washing Sink	16	12/21/2021	7:58 AM	2-3 Minutes	Water Sampling
High School 2nd Floor Cafeteria	17	12/21/2021	8:00 AM	2-3 Minutes	Water Sampling

## Beloved Community Charter School Sampling Plan

Date: 01/06/2022

Water Bottle Station					
High School 2nd Floor Men's Room Center Sink	18	12/21/2021	8:01 AM	2-3 Minutes	Water Sampling
High School 2nd Floor Women's Room Center Sink	19	12/21/2021	8:01 AM	2-3 Minutes	Water Sampling
High School 2nd Floor Water Bottle Station Near Nurses' Office	20	12/21/2021	8:02 AM	2-3 Minutes	Water Sampling
High School 2nd Floor Nurse's Office Sink	21	12/21/2021	8:04 AM	2-3 Minutes	Water Sampling
High School 2nd Floor Nurses' Office Bathroom Sink	22	12/21/2021	8:04 AM	2-3 Minutes	Water Sampling
High School 2nd Floor Staff Bathroom 110 Sink	23	12/21/2021	8:05 AM	2-3 Minutes	Water Sampling
High School 3rd Floor Men's Room 217 Sink Center	24	12/21/2021	8:06 AM	2-3 Minutes	Water Sampling
High School 3rd Floor Women's Room 215 Sink Center	25	12/21/2021	8:06 AM	2-3 Minutes	Water Sampling
High School 3rd Floor Bottle Station Near 208B	26	12/21/2021	8:07 AM	2-3 Minutes	Water Sampling
High School 3rd Floor Staff Bathroom 210	27	12/21/2021	8:08 AM	2-3 Minutes	Water Sampling
High School 4th Floor Men's Room 317 Sink Center	28	12/21/2021	8:10 AM	2-3 Minutes	Water Sampling

High School 4th Floor Women's Room 315 Sink Center	29	12/21/2021	8:12 AM	2-3 Minutes	Water Sampling
High School 4th Floor Water Bottle Station Near 312	30	12/21/2021	8:13 AM	2-3 Minutes	Water Sampling
High School 4th Floor Staff Bathroom 310 Sink	31	12/21/2021	8:18 AM	2-3 Minutes	Water Sampling
High School 4th Floor Staff Bathroom 308 Sink	32	12/21/2021	8:19 AM	2-3 Minutes	Water Sampling

## Attachment F - Pre - Sampling Water Use Certification

TO BE COMPLETED BY THE BELOVED COMMUNITY CHARTER SCHOOL REPRESENTATIVE:		
School Name: <u>Beloved Community Charter School</u>		
Sample collection address:	<u>508 Grand Street, Jersey City, New Jersey 07302</u>	
Water was last used:	<u>Time: 3:00 PM</u>	<u>Date: 12/20/21</u>
Sample commencement:	<u>Time: 7:35 AM</u>	<u>Date: 12/21/21</u>
I have read the Lead Drinking Water Testing Sampling Plan and Quality Assurance Project Plan and I am certifying that samples were collected in accordance with these plans.		
Duanne Moeller	<u>01/06/2022</u>	
Signature	Date	

## Attachment G - Example of a Sample Flush Tag

### FLUSH TAG

**Water outlet sampling in progress. Please do not use water**

School District Name:

Date Flushed:

School Name: Beloved Community Charter School

Flushing Process

School Address: 508 Grand Street, Jersey City, New Jersey 07302

Start Time:

Location of flushed outlet:

End Time:

Is the fountain front cover removed for the sampler to determine the reservoir type (circle one):

YES / NO

Person responsible for the flushing process (print name): \_\_\_\_\_

Signature: \_\_\_\_\_

\* Water within the school distribution system should sit in the pipes unused for at least eight (8) hours after flushing but not more than 48 hours before a sample is taken.\*

*Note to the person responsible for the flushing process:*

- A. Turn-off lawn sprinkler outlet(s) until water sampling is complete.
- B. Make sure sampling outlets are accessible.

**DO NOT DRINK**



**SAFE FOR HANDWASHING**

